

Legislation Text

File #: 2018-2025, **Version:** 3

Hazardous Materials Permit for KC Dumpster Co. located at 1280 SE Century Drive.

Rody Taylor with KC Dumpster submitted a Hazardous Materials Permit application for a 3,000-gallon diesel fuel tank and dispenser for fueling trucks associated with the business. Also included in the application were materials used for vehicle maintenance. The 3,000-gallons of diesel fuel is in excess of the 10,000 lbs Threshold Planning Quantity (TPQ) set forth in the Emergency Planning and Community Right-to-Know Act of 1986 (SARA TITLE III, EPCRA). Whereas Ordinance No. 7370 requires a Hazardous Materials Permit for quantities above Threshold Planning Quantity (TPQ), a permit is required. The location of the tank, equipment, and other appurtenances met the requirements of the 2012 International Fire Code. All conditions will be inspected before the permit is issued.

Staff recommends APPROVAL of the application.

On April 17, 2018, the Public Safety Advisory Board voted unanimously to RECOMMEND APPROVAL of the Hazardous Material Permit for KC Dumpster located at 1280 SE Century Drive; and for it to be submitted to the City Council for review. None opposed.